



GAS SAFETY CERTIFICATE

CERTIFICATE REF: GS/560

CONTRACTOR DETAILS		APPLIANCE DETAILS							
	Plumbwise 19 De Beauvoir Court Islington		LOCATION	TYPE	MANUFACTURER	MODEL	OWNERSHIP	FLUE TYPE	SERVICED
		1	KITCHEN	BOILER	VISSMANN	VITODENS 100W	LANDLORD	ROOM SEALED	YES
		2	KENWOOD	RANGE COOKER	KENWOOD	CK405	LANDLORD	FLUELESS	NO
		3							
		4							
Gas Safe Register: 577688 Telephone: 03330164117		INSPECTION DETAILS							
			OP (MBAR)	HI (KW)	VENTILATION	FLUE VISUAL	FLUE OPERATION	COMBUSTION RATIO	SAFE TO USE
INSTALLATION DETAILS		1	21MB		PASS	PASS	PASS	0.0002	YES
Flat 25, First Floor Vyner Street London E2 9DG		2	22MB		PASS	NA	NA	NA	YES
		3							
		4							
		DEFECTS IDENTIFIED							
Telephone:		1							
CLIENT DETAILS		2							
jennie Fagerstrom / VWP Ltd, Limewharf Flat 25, First Floor Vyner Street London E2 9DG		3							
		4							
		REMEDIAL ACTION TAKEN							
		1							
		2							
		3							
Telephone:		4							
INSTALLATION DETAILS		CO ALARM			ENGINEER NOTES				
INSTALLATION PIPEWORK VISUAL	PASS	APPROVED ALARM FITTED	NO						
SUPPLY PIPEWORK VISUAL	PASS	ALARM TEST							
PROTECTIVE EQUIPOTENTIAL BONDING	PASS								
TIGHTNESS TEST	PASS								
TIGHTNESS TEST RESULT	ZERO DROP								
ECV ACCESS	PASS	Engineer Name: Daniel Allen			Client:		Date: 31/03/2021		
NO. APPLIANCES TESTED	2	Gas ID Number: 4410925			Next safety check due by: 31st March 2022				