



GAS SAFETY CERTIFICATE

CERTIFICATE REF: GS/559

CONTRACTOR DETAILS		APPLIANCE DETAILS							
	Plumbwise 19 De Beauvoir Court Islington		LOCATION	TYPE	MANUFACTURER	MODEL	OWNERSHIP	FLUE TYPE	SERVICED
		1	SHOWER ROOM	BOILER	WORCESTER	GREENSTAR 30i ERP	LANDLORD	ROOM SEALED	YES
		2	KITCHEN	RANGE COOKER	LACANCHE	UNKNOWN	LANDLORD	FLUELESS	YES
		3							
		4							
Gas Safe Register: 577688 Telephone: 03330164117		INSPECTION DETAILS							
INSTALLATION DETAILS			OP (MBAR)	HI (KW)	VENTILATION	FLUE VISUAL	FLUE OPERATION	COMBUSTION RATIO	SAFE TO USE
Flat 1 Lime Wharf, Vyner Street London E2 9DJ		1	19		PASS	PASS	PASS	0.0003	YES
		2	19		PASS	NA	NA	NA	YES
		3							
		4							
		DEFECTS IDENTIFIED							
Telephone:		1							
CLIENT DETAILS		2							
Jennie Fagerstrom / VWP Ltd, Limewharf Flat 1 Lime Wharf, Vyner Street London E2 9DJ		3							
		4							
		REMEDIAL ACTION TAKEN							
		1							
		2							
		3							
Telephone:		4							
INSTALLATION DETAILS		CO ALARM			ENGINEER NOTES				
INSTALLATION PIPEWORK VISUAL	PASS	APPROVED ALARM FITTED		NO					
SUPPLY PIPEWORK VISUAL	PASS	ALARM TEST							
PROTECTIVE EQUIPOTENTIAL BONDING	PASS								
TIGHTNESS TEST	PASS								
TIGHTNESS TEST RESULT	ZERO DROP								
ECV ACCESS	PASS	Engineer Name: Sam Sinclair				Client:		Date: 1/04/2021	
NO. APPLIANCES TESTED	2	Gas ID Number: 4410925				Next safety check due by: 1st April 2022			