



GAS SAFETY CERTIFICATE

CERTIFICATE REF: GS/562

CONTRACTOR DETAILS		APPLIANCE DETAILS							
 Plumbwise 19 De Beauvoir Court Islington		LOCATION	TYPE	MANUFACTURER	MODEL	OWNERSHIP	FLUE TYPE	SERVICED	
	1	FRONT OFFICE	BOILER	VAILLANT	ECOTEC PLUS 825	LANDLORD	ROOM SEALED	YES	
	2								
	3								
	4								
Gas Safe Register: 577688 Telephone: 03330164117		INSPECTION DETAILS							
INSTALLATION DETAILS			OP (MBAR)	HI (KW)	VENTILATION	FLUE VISUAL	FLUE OPERATION	COMBUSTION RATIO	SAFE TO USE
Ground floor, 25/25a Vyner Street London E2 9DG		1	20MB		PASS	PASS	PASS	0.0006	YES
		2							
		3							
		4							
		DEFECTS IDENTIFIED							
		1	NO EARTH BONDING ON METER						NCS
Telephone:		2							
CLIENT DETAILS		3							
jennie Fagerstrom / VWP Ltd, Limewharf Ground floor, 25/25a Vyner Street London E2 9DG		4							
		REMEDIAL ACTION TAKEN							
		1	ADVISE CLIENT						
		2							
		3							
Telephone:		4							
INSTALLATION DETAILS		CO ALARM			ENGINEER NOTES				
INSTALLATION PIPEWORK VISUAL	PASS	APPROVED ALARM FITTED	NO	METER NEEDS TO BE BONDED					
SUPPLY PIPEWORK VISUAL	PASS	ALARM TEST							
PROTECTIVE EQUIPOTENTIAL BONDING	FAIL								
TIGHTNESS TEST	PASS								
TIGHTNESS TEST RESULT	ZERO DROP								
ECV ACCESS	PASS	Engineer Name: Daniel Allen			Client:		Date: 31/03/2021		
NO. APPLIANCES TESTED	1	Gas ID Number: 4410925			Next safety check due by: 31st March 2022				