



GAS SAFETY CERTIFICATE

CERTIFICATE REF: GS/563

CONTRACTOR DETAILS		APPLIANCE DETAILS						
 Plumbwise 19 De Beauvoir Court Islington		LOCATION	TYPE	MANUFACTURER	MODEL	OWNERSHIP	FLUE TYPE	SERVICED
	1	OFFICE	BOILER	WORCESTER BOSCH	GREENSTAR 29CDI CLASSIC	LANDLORD	ROOM SEALED	YES
	2							
	3							
	4							
Gas Safe Register: 577688 Telephone: 03330164117		INSPECTION DETAILS						
		OP (MBAR)	HI (KW)	VENTILATION	FLUE VISUAL	FLUE OPERATION	COMBUSTION RATIO	SAFE TO USE
INSTALLATION DETAILS		1	20	PASS	PASS	PASS	0.0004	YES
Unit 1 Ground Floor Vyner Street London E2 9DJ		2						
		3						
		4						
		DEFECTS IDENTIFIED						
Telephone:		1						
CLIENT DETAILS		2						
Jennie Fagerstrom / VWP Ltd, Limewharf Unit 1 Ground Floor Vyner Street London E2 9DG		3						
		4						
		REMEDIAL ACTION TAKEN						
		1						
		2						
		3						
Telephone:		4						
INSTALLATION DETAILS		CO ALARM			ENGINEER NOTES			
INSTALLATION PIPEWORK VISUAL	PASS	APPROVED ALARM FITTED	NO					
SUPPLY PIPEWORK VISUAL	PASS	ALARM TEST						
PROTECTIVE EQUIPOTENTIAL BONDING	PASS							
TIGHTNESS TEST	PASS							
TIGHTNESS TEST RESULT	ZERO DROP							
ECV ACCESS	PASS	Engineer Name: Sam Sinclair			Client:		Date: 1/04/2021	
NO. APPLIANCES TESTED	1	Gas ID Number: 4410925			Next safety check due by: 1st April 2022			