



GAS SAFETY CERTIFICATE

CERTIFICATE REF: GS/561

CONTRACTOR DETAILS		APPLIANCE DETAILS							
	Plumbwise 19 De Beauvoir Court Islington		LOCATION	TYPE	MANUFACTURER	MODEL	OWNERSHIP	FLUE TYPE	SERVICED
		1	KITCHEN	BOILER	VAILLANT	ECOFIT PURE 830	LANDLORD	ROOM SEALED	YES
		2	KITCHEN	HOB	SCHOLTES	PP30TC120	LANDLORD	FLUELESS	NO
		3							
		4							
Gas Safe Register: 577688 Telephone: 03330164117		INSPECTION DETAILS							
			OP (MBAR)	HI (KW)	VENTILATION	FLUE VISUAL	FLUE OPERATION	COMBUSTION RATIO	SAFE TO USE
INSTALLATION DETAILS		1	19MB		PASS	PASS	PASS	0.0004	YES
Flat 25a First Floor Vyner Street London E2 9DG		2	19MB		PASS	NA	NA	NA	YES
		3							
		4							
		DEFECTS IDENTIFIED							
Telephone:		1							
CLIENT DETAILS		2							
jennie Fagerstrom / VWP Ltd, Limewharf Flat 25a First Floor Vyner Street London E2 9DG		3							
		4							
		REMEDIAL ACTION TAKEN							
		1							
Telephone:		2							
		3							
		4							
INSTALLATION DETAILS		CO ALARM			ENGINEER NOTES				
INSTALLATION PIPEWORK VISUAL	PASS	APPROVED ALARM FITTED		NO					
SUPPLY PIPEWORK VISUAL	PASS	ALARM TEST							
PROTECTIVE EQUIPOTENTIAL BONDING	PASS								
TIGHTNESS TEST	PASS								
TIGHTNESS TEST RESULT	ZERO								
ECV ACCESS	PASS	Engineer Name: Daniel Allen				Client:		Date: 31/03/2021	
NO. APPLIANCES TESTED	2	Gas ID Number: 4410925				Next safety check due by: 31st March 2022			